Stricken language would be deleted from and underlined language would be added to present law. Act 565 of the Regular Session

1	State of Arkansas	A Bill	
2	89th General Assembly	A DIII	
3	Regular Session, 2013		SENATE BILL 840
4			
5	By: Senator Elliott		
6	By: Representative Cozart		
7		For An Ast To Do Entitled	
8	For An Act To Be Entitled		
9	AN ACT TO REPEAL THE REQUIREMENT THAT LOW VOLTAGE		
10	CARBON MONOXIDE DETECTORS BE PLACED IN NEWLY CONSTRUCTED HOMES; AND FOR OTHER PURPOSES.		
11	CONSTRUCTED I	HOMES; AND FOR OTHER PURPOSES.	
12			
13		Subtitle	
14	TO REPEAL THE REQUIREMENT THAT LOW		
15		·	
16 17		CARBON MONOXIDE DETECTORS BE	
17	PLACED	IN NEWLY CONSTRUCTED HOMES.	
10			
20	ΒΕ ΤΤ ΕΝΛΟΤΕΊ ΒΥ ΤΗΕ ΩΕΝΙ	ERAL ASSEMBLY OF THE STATE OF ARKA	ANGAG.
21	DE II ENROIED DI INE GEN	INAL AUDITOR OF THE STATE OF AND	ANDAD.
22	SECTION 1. Arkansa	as Code § 20-7-138 is repealed.	
23		tage carbon monoxide detectors red	quired in new home
24	construction.	0	-
25	<del>(a) For a new hom</del> e	e constructed after January 1, 20	<del>12, a low-voltage</del>
26	carbon monoxide alarm sha	all be installed on each floor.	
27	(b) <u>A low-voltage</u>	carbon monoxide alarm may receive	<del>e primary power</del>
28	from:		
29	(1) The buil	lding wiring if the wiring is serv	ved from an on-site
30	electrical power system;	<del>-01</del>	
31	<del>(2) A batte</del>	<del>ry.</del>	
32	(c)(l) A combinat:	ion smoke and low-voltage carbon a	m <del>onoxide alarm may</del>
33	be installed if the manufacturer lists the alarm for combination use.		
34	<del>(2) A combin</del>	nation smoke and low-voltage carbo	o <del>n monoxide alarm</del>
35	shall have distinctly di	fferent alarm signals for smoke a	<del>larm or low-voltage</del>
36	<del>carbon monoxide alarm ac</del>	tivation.	



.

1	(d) A low-voltage carbon monoxide alarm shall not be located:
2	(1) Within or near the openings to garages, bathrooms, or
3	furnace rooms;
4	(2) In or near locations specified as "prohibited", "not
5	recommended", or a similar specification in the manufacturer's installation
6	instructions; or
7	(3) More than three (3) feet above the floor.
8	(e) Except for service or repair, a low-voltage carbon monoxide alarm
9	shall not be removed or disabled.
10	(f) A person who pleads guilty or nolo contendere to or is found
11	guilty of violating this section is guilty of a Class A misdemeanor.
12	(g) This section does not apply to all-electric homes.
13	
14	
15	APPROVED: 04/02/2013
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	
26	
27	
28	
29	
30	
31	
32	
33	
34	
35	
36	

2